# ADA TRANSITION PLAN 2015 - 2019

FURNITURE-RELATED ITEMS

OCTOBER 30, 2019


# 2

## ADA-Compliant Table Dimensions

At least five percent of seating (and no less than one) must be a minimum of:

- 27 inches High
- 30 inches Wide
- 19 inches Deep
- 19 inches deep

Tables cannot exceed 34 inches in height.






# Boykin Hall

## 3 items corrected

Lab Classes 207 & 208 - Lab Stations

Labs remodeled with new lab stations




# Coffee Kiosk

## 1 item corrected

#### Patio Seating

 New type of table added meeting 27"H x 30"W x 19"D requirements to allow for wheelchair access





4



# East Physical Education (EPEK)


#### 1 item corrected

#### Classrooms 101, 102, and 103

 3 designated ADAcompliant tables were found elsewhere and were relocated to appropriate classrooms

#### Before





# Hasley Hall

## 5 items corrected

#### Computer Labs 206, 302-306

 6 new ADA-compliant computer tables installed

#### Before





# Hasley Hall

## 5 items corrected

Classrooms 135, 203-205, 230, 232, 235

- Modesty panel infringing on minimum required depth
- 7 new ADA-compliant classroom tables without modesty panels installed

## Before





## After

- Quantity of seven (7): 24" x 60" classroom tables, Fixed height (at least 28" high knee space), and T-leg with glide on VCT
- Finish: Charcoal laminate/edgeband, and silver metallic legs (or silver whatever is standard)
- TAG: HH135, 203-205, 230, 232 & 235

٠





## Library

#### 26 items corrected

Group Study Rooms 110, 209, 210, 230

- 1/4" drum base infringing on minimum required depth
- Removed drum base and replaced with table legs

#### Before







## Library


## 26 items corrected

#### Open Areas 1<sup>st</sup> and 2<sup>nd</sup> Floor

- Table legs infringing on minimum required depth
- 3 ADA-compliant, adjustable height tables with privacy screens installed

#### Before









## Library

### 26 items corrected

Open Areas 1<sup>st</sup> and 2<sup>nd</sup> Floor

- Study carrels did not meet minimum required width & height
- Replaced old study carrels with ADA-compliant study carrels

#### Before



# 10






# Mentry Hall

## 9 items corrected

#### Photo Rooms 129,133 and Life Drawing Room 245

- ADA-compliant computer table installed
- Microwave without knobs
  installed

#### Before











## Mentry Hall

## 9 items corrected

#### Classroom 234 & 301

- Tables did not meet minimum depth requirements
- New ADA-compliant classroom table installed
- New ADA-compliant drafting table installed

#### Before











# Outdoor Area Hasley Hall & East PE

## 2 items corrected

 2 New ADA-compliant outdoor tables installed with opening for wheelchair access

## Before







# Seco Hall

## 5 items corrected

#### DSPS Department


- Base infringing upon minimum depth & width
- New ADA-compliant conference table and computer lab table installed





After





# Seco Hall


## 5 items corrected


#### 3<sup>rd</sup> Floor Outdoor Seating Area

- New ADA-compliant picnic table installed
- Allows wheelchair to sit in middle of table, not at the end

#### Before

After





## Student Center


#### 4 items corrected

#### ASG Computer Lab And

#### Cafeteria Dining Area

- Star table base infringing upon minimum depth requirement
- 4 new ADA-compliant tables

#### Before









# Student Support Center

## 1 item corrected

#### Classrooms 118 & 119

• 3 ADA-compliant tables found in 118, moved to 119





After



# Towsley Hall

#### 3 items corrected


Welding Area Rooms 123 & 125

Work surface exceeded maximum height

Two new ADA-compliant, stainless steel tables installed



Before



# Towsley Hall

## 3 items corrected

Towsley #104 – MLT/Phlebotomy Lab

 Printer and other items that were blocking ADA-compliant workstation were removed





# West Physical Education (WPEK)

#### 1 item corrected

#### Classroom #108


- Tablet-arm chairs infringed upon minimum depth & width
- New ADA-compliant
  classroom tables installed

#### Before



# After

FLOOR PLAN






# Performing Arts Center (PAC)


1 item to be corrected Due by 12/31/19

Balcony dining table with drum base to be replaced with 4 legged ADA-compliant table



Proposed After





## The Learning Center (TLC)

## 21 items to be corrected

#### Due by 12/31/19

- Large Study Room: Purchase
  ADA-compliant computer table
- <u>Assessment Center</u>: Remove keyboard trays from 2 tables
- <u>4 Computer Labs:</u> Purchase 1-2 ADA-compliant computer tables for each lab
- <u>Testing Room</u>: Purchase 1 ADAcompliant classroom table
- Open Area: Purchase 4-5 new ADA-compliant tables

#### Before




## University Center

## 14 items to be corrected

#### Due by 12/31/19

- <u>Café & Lounge Areas</u>: Purchase 3 ADA-compliant tables
- Lecture Room: Purchase deeper tables for front row
- <u>Patio</u>: Purchase ADA-compliant patio table
- <u>Classrooms</u>: Purchase 1-2 ADAcompliant table for each classroom

#### Before









# Summary

Building	Furniture-Related Items
Boykin Hall	3
Coffee Kiosk	1
East PE	1
Hasley Hall	5
Library	26
Mentry Hall	9
Outdoor Area (Hasley)	2
Performing Arts Center	1
Seco Hall	5
Student Center	4
Student Support Center	1
The Learning Center (TLC)	21
Towsley	3
University Center	14
West PE	1
TC	OTAL 97

# Questions?